



- NOTES:
1. MAXIMUM TRAVEL IS 25'0".
 2. PIT FLOOR TO BE DESIGNED FOR A LOAD OF 5800 lbs.
 3. BUFFER SPRINGS SET FOR 2" STD. UNDERTRAVEL.
 4. IF OPPOSITE OPENING IS LESS THAN 18" FLOOR TO FLOOR CONSULT FACTORY.

1. REDUCTION OF PIT FROM 38" REQUIRES BOTTOM CAR CLEARANCE DEVICE OPTION. 14" MIN. PIT REQUIRED W/ OPTION.
2. IN EXISTING BUILDING, REDUCTION OF OVERHEAD FROM 10'9" REQUIRES TOP CAR CLEARANCE DEVICE OPTION. 9'6" MIN. CLEAR OVERHEAD REQUIRED W/ OPTION.
3. PITS OVER 36" REQUIRE PIT LADDERS (BY OTHERS).

- A- PIT LIGHT SWITCH BY G.C. 4'0" ABOVE FINISHED FLOOR
- B- PIT STOP SWITCH BY MFG 1'6" ABOVE FINISHED FLOOR
- C- PIT LIGHT AND OUTLET BY G.C.
- D- LIGHT AND OUTLET BY G.C.

PLEASE INDICATE WHETHER AN A OR B DOOR. ALSO, PLEASE INDICATE WHICH IS THE MAIN FLOOR.

FRONT WALL THICKNESS AND TYPE AT EACH LANDING					
FLR	MAIN FLR	A/B DOOR	BRILLE SYMBOL	THKNSS	WALL TYPE
1				5"	DW/CMU
2				5"	DW/CMU
3				5"	DW/CMU
4				5"	DW/CMU

ACCREDITED HOME ELEVATOR
www.acelevator.com
 1-800-488-5905